

Glass curtain - **Standard Serie**

## TRIAL **RESISTANCE** TO WIND LOAD AND AIR PERMEABILITY

### **Tested Material**

Aluminum and glass Closing model Glass curtain with a double shutter, one of them also sliding, with a total dimension of 3000 x 1268 mm (height and width), glass thickness 12 mm.

### **Requested Tests**

Initial type testing according to requirements:

UNE- EN 1026:2000 "Windows and Doors. Air Permeability, testing method".

UNE – EN 12211:2000 "Windows and Doors. Resistance to wind load, testing method".

### **Conclusions of the trials**

Resistance to wind load

*Class C = Arrow minor than 1/300*

*Class 3 = Safety Shock 1800 Pa*

Air permeability

*Class 0*



**Juan Carlos Moreno**  
Manager

Málaga, October 4th, 2013