

Glass curtain - **Standard Serie**

## TRIAL **RESISTANCE** TO WIND LOAD AND AIR PERMEABILITY

### Tested Material

Aluminum and glass Closing model Glass curtain with a double shutter, one of them also sliding, with a total dimension of 1680 x 1160 mm (height and width), glass thickness 10 mm.

### Requested Tests

Initial type testing according to requirements:

UNE-EN 1026:2000 "Windows and Doors. Air Permeability, testing method".

UNE-EN 12211:2000 "Windows and Doors. Resistance to wind load, testing method".

### Conclusions of the trials

Resistance to wind load

Class C=Arrow minor than 1/300

Class 3 =Safety Shock 1800 Pa

Air permeability

**Class 0**



**Juan Carlos Moreno**  
Manager

Málaga, October 4th, 2013